



Lower Capacity Units

200 mg/hr

	Dimensions		VOLUME	MACHINE OUTPUT	TIME REQUIRED TO DISINFECT
	Square Feet	Ceiling Height	Cubic Feet	Grams Per Hour	Hours
Individual Office and Rooms	200	10	2000	0.2	10.00
Average Apartment	882	10	8820	0.2	44.10
Average House	2392	10	23920	0.2	119.60

250 mg/hr

	Dimensions		VOLUME	MACHINE OUTPUT	TIME REQUIRED TO DISINFECT
	Square Feet	Ceiling Height	Cubic Feet	Grams Per Hour	Hours
Individual Office and Rooms	200	10	2000	0.25	8.00
Average Apartment	882	10	8820	0.25	35.28
Average House	2392	10	23920	0.25	95.68

400 mg/hr

	Dimensions		VOLUME	MACHINE OUTPUT	TIME REQUIRED TO DISINFECT
	Square Feet	Ceiling Height	Cubic Feet	Grams Per Hour	Hours
Individual Office and Rooms	200	10	2000	0.4	5.00
Average Apartment	882	10	8820	0.4	22.05
Average House	2392	10	23920	0.4	59.80

600 mg/hr

	Dimensions		VOLUME	MACHINE OUTPUT	TIME REQUIRED TO DISINFECT
	Square Feet	Ceiling Height	Cubic Feet	Grams Per Hour	Hours
Individual Office and Rooms	200	10	2000	0.6	3.33
Average Apartment	882	10	8820	0.6	14.70
Average House	2392	10	23920	0.6	39.87

2000 mg/hr

Dimensions	VOLUME	MACHINE OUTPUT	TIME REQUIRED TO DISINFECT
------------	--------	----------------	----------------------------



	Square Feet	Ceiling Height	Cubic Feet	Grams Per Hour	Hours
Individual Office and Rooms	200	10	2000	2	1.00
Average Apartment	882	10	8820	2	4.41
Average House	2392	10	23920	2	11.96
Office Space/Commercial Space	5000	10	50000	2	25.00
Office Space/Commercial Space	10000	10	100000	2	50.00

Mid-Size Capacity

5 grams/hr

	Dimensions		VOLUME	MACHINE OUTPUT	TIME REQUIRED TO DISINFECT
	Square Feet	Ceiling Height	Cubic Feet	Grams Per Hour	Hours
Individual Office and Rooms	200	10	2000	5	0.40
Average Apartment	882	10	8820	5	1.76
Average House	2392	10	23920	5	4.78
Office Space/Commercial Space	5000	10	50000	5	10.00
Office Space/Commercial Space	10000	10	100000	5	20.00
Office Space/Commercial Space	20000	10	200000	5	40.00
Office Space/Commercial Space	30000	10	300000	5	60.00
Office Space/Commercial Space	40000	10	400000	5	80.00
Office Space/Commercial Space	50000	10	500000	5	100.00
Warehouse/Industrial Space	5000	18	90000	5	18.00
Warehouse/Industrial Space	10000	18	180000	5	36.00
Warehouse/Industrial Space	20000	18	360000	5	72.00
Warehouse/Industrial Space	30000	18	540000	5	108.00
Warehouse/Industrial Space	40000	18	720000	5	144.00
Warehouse/Industrial Space	50000	18	900000	5	180.00

10 grams/hr

	Dimensions		VOLUME	MACHINE OUTPUT	TIME REQUIRED TO DISINFECT
	Square Feet	Ceiling Height	Cubic Feet	Grams Per Hour	Hours
Individual Office and Rooms	200	10	2000	10	0.20
Average Apartment	882	10	8820	10	0.88
Average House	2392	10	23920	10	2.39
Office Space/Commercial Space	5000	10	50000	10	5.00
Office Space/Commercial Space	10000	10	100000	10	10.00
Office Space/Commercial Space	20000	10	200000	10	20.00



Office Space/Commercial Space
 Office Space/Commercial Space
 Office Space/Commercial Space
 Warehouse/Industrial Space
 Warehouse/Industrial Space
 Warehouse/Industrial Space
 Warehouse/Industrial Space
 Warehouse/Industrial Space
 Warehouse/Industrial Space

30000	10	300000	10	30.00
40000	10	400000	10	40.00
50000	10	500000	10	50.00
5000	18	90000	10	9.00
10000	18	180000	10	18.00
20000	18	360000	10	36.00
30000	18	540000	10	54.00
40000	18	720000	10	72.00
50000	18	900000	10	90.00

15 grams/hr

Individual Office and Rooms
 Average Apartment
 Average House
 Office Space/Commercial Space
 Office Space/Commercial Space
 Office Space/Commercial Space
 Office Space/Commercial Space
 Office Space/Commercial Space
 Office Space/Commercial Space
 Warehouse/Industrial Space
 Warehouse/Industrial Space
 Warehouse/Industrial Space
 Warehouse/Industrial Space
 Warehouse/Industrial Space
 Warehouse/Industrial Space

Dimensions		VOLUME	MACHINE OUTPUT	TIME REQUIRED TO DISINFECT
Square Feet	Ceiling Height	Cubic Feet	Grams Per Hour	Hours
200	10	2000	15	0.13
882	10	8820	15	0.59
2392	10	23920	15	1.59
5000	10	50000	15	3.33
10000	10	100000	15	6.67
20000	10	200000	15	13.33
30000	10	300000	15	20.00
40000	10	400000	15	26.67
50000	10	500000	15	33.33
5000	18	90000	15	6.00
10000	18	180000	15	12.00
20000	18	360000	15	24.00
30000	18	540000	15	36.00
40000	18	720000	15	48.00
50000	18	900000	15	60.00

20 grams/hr

Individual Office and Rooms
 Average Apartment
 Average House
 Office Space/Commercial Space

Dimensions		VOLUME	MACHINE OUTPUT	TIME REQUIRED TO DISINFECT
Square Feet	Ceiling Height	Cubic Feet	Grams Per Hour	Hours
200	10	2000	20	0.10
882	10	8820	20	0.44
2392	10	23920	20	1.20
5000	10	50000	20	2.50



Office Space/Commercial Space
 Office Space/Commercial Space
 Office Space/Commercial Space
 Office Space/Commercial Space
 Office Space/Commercial Space
 Warehouse/Industrial Space
 Warehouse/Industrial Space
 Warehouse/Industrial Space
 Warehouse/Industrial Space
 Warehouse/Industrial Space
 Warehouse/Industrial Space

10000	10	100000	20	5.00
20000	10	200000	20	10.00
30000	10	300000	20	15.00
40000	10	400000	20	20.00
50000	10	500000	20	25.00
5000	18	90000	20	4.50
10000	18	180000	20	9.00
20000	18	360000	20	18.00
30000	18	540000	20	27.00
40000	18	720000	20	36.00
50000	18	900000	20	45.00

25 grams/hr

Individual Office and Rooms
 Average Apartment
 Average House
 Office Space/Commercial Space
 Office Space/Commercial Space
 Office Space/Commercial Space
 Office Space/Commercial Space
 Office Space/Commercial Space
 Office Space/Commercial Space
 Warehouse/Industrial Space
 Warehouse/Industrial Space
 Warehouse/Industrial Space
 Warehouse/Industrial Space
 Warehouse/Industrial Space
 Warehouse/Industrial Space

Dimensions		VOLUME	MACHINE OUTPUT	TIME REQUIRED TO DISINFECT
Square Feet	Ceiling Height	Cubic Feet	Grams Per Hour	Hours
200	10	2000	25	0.08
882	10	8820	25	0.35
2392	10	23920	25	0.96
5000	10	50000	25	2.00
10000	10	100000	25	4.00
20000	10	200000	25	8.00
30000	10	300000	25	12.00
40000	10	400000	25	16.00
50000	10	500000	25	20.00
5000	18	90000	25	3.60
10000	18	180000	25	7.20
20000	18	360000	25	14.40
30000	18	540000	25	21.60
40000	18	720000	25	28.80
50000	18	900000	25	36.00

30 grams/hr

Individual Office and Rooms
 Average Apartment

Dimensions		VOLUME	MACHINE OUTPUT	TIME REQUIRED TO DISINFECT
Square Feet	Ceiling Height	Cubic Feet	Grams Per Hour	Hours
200	10	2000	30	0.07
882	10	8820	30	0.29



Average House
 Office Space/Commercial Space
 Office Space/Commercial Space
 Office Space/Commercial Space
 Office Space/Commercial Space
 Office Space/Commercial Space
 Office Space/Commercial Space
 Warehouse/Industrial Space
 Warehouse/Industrial Space
 Warehouse/Industrial Space
 Warehouse/Industrial Space
 Warehouse/Industrial Space
 Warehouse/Industrial Space

2392	10	23920	30	0.80
5000	10	50000	30	1.67
10000	10	100000	30	3.33
20000	10	200000	30	6.67
30000	10	300000	30	10.00
40000	10	400000	30	13.33
50000	10	500000	30	16.67
5000	18	90000	30	3.00
10000	18	180000	30	6.00
20000	18	360000	30	12.00
30000	18	540000	30	18.00
40000	18	720000	30	24.00
50000	18	900000	30	30.00

35 grams/hr

Individual Office and Rooms
 Average Apartment
 Average House
 Office Space/Commercial Space
 Office Space/Commercial Space
 Office Space/Commercial Space
 Office Space/Commercial Space
 Office Space/Commercial Space
 Office Space/Commercial Space
 Office Space/Commercial Space
 Warehouse/Industrial Space
 Warehouse/Industrial Space
 Warehouse/Industrial Space
 Warehouse/Industrial Space
 Warehouse/Industrial Space
 Warehouse/Industrial Space

Dimensions		VOLUME	MACHINE OUTPUT	TIME REQUIRED TO DISINFECT
Square Feet	Ceiling Height	Cubic Feet	Grams Per Hour	Hours
200	10	2000	35	0.06
882	10	8820	35	0.25
2392	10	23920	35	0.68
5000	10	50000	35	1.43
10000	10	100000	35	2.86
20000	10	200000	35	5.71
30000	10	300000	35	8.57
40000	10	400000	35	11.43
50000	10	500000	35	14.29
5000	18	90000	35	2.57
10000	18	180000	35	5.14
20000	18	360000	35	10.29
30000	18	540000	35	15.43
40000	18	720000	35	20.57
50000	18	900000	35	25.71

40 grams/hr

Dimensions		VOLUME	MACHINE OUTPUT	TIME REQUIRED TO DISINFECT
Square Feet	Ceiling Height	Cubic Feet	Grams Per Hour	Hours



Individual Office and Rooms	200	10	2000	40	0.05
Average Apartment	882	10	8820	40	0.22
Average House	2392	10	23920	40	0.60
Office Space/Commercial Space	5000	10	50000	40	1.25
Office Space/Commercial Space	10000	10	100000	40	2.50
Office Space/Commercial Space	20000	10	200000	40	5.00
Office Space/Commercial Space	30000	10	300000	40	7.50
Office Space/Commercial Space	40000	10	400000	40	10.00
Office Space/Commercial Space	50000	10	500000	40	12.50
Warehouse/Industrial Space	5000	18	90000	40	2.25
Warehouse/Industrial Space	10000	18	180000	40	4.50
Warehouse/Industrial Space	20000	18	360000	40	9.00
Warehouse/Industrial Space	30000	18	540000	40	13.50
Warehouse/Industrial Space	40000	18	720000	40	18.00
Warehouse/Industrial Space	50000	18	900000	40	22.50

High Capacity Commercial Units

50 grams/hr

	Dimensions		VOLUME	MACHINE OUTPUT	TIME REQUIRED TO DISINFECT
	Square Feet	Ceiling Height	Cubic Feet	Grams Per Hour	Hours
Office Space/Commercial Space	5000	10	50000	50	1.00
Office Space/Commercial Space	10000	10	100000	50	2.00
Office Space/Commercial Space	20000	10	200000	50	4.00
Office Space/Commercial Space	30000	10	300000	50	6.00
Office Space/Commercial Space	40000	10	400000	50	8.00
Office Space/Commercial Space	50000	10	500000	50	10.00
Warehouse/Industrial Space	5000	18	90000	50	1.80
Warehouse/Industrial Space	10000	18	180000	50	3.60
Warehouse/Industrial Space	20000	18	360000	50	7.20
Warehouse/Industrial Space	30000	18	540000	50	10.80
Warehouse/Industrial Space	40000	18	720000	50	14.40
Warehouse/Industrial Space	50000	18	900000	50	18.00

70 grams/hr

Dimensions VOLUME MACHINE OUTPUT TIME REQUIRED TO DISINFECT



	Square Feet	Ceiling Height	Cubic Feet	Grams Per Hour	Hours
Office Space/Commercial Space	5000	10	50000	70	0.71
Office Space/Commercial Space	10000	10	100000	70	1.43
Office Space/Commercial Space	20000	10	200000	70	2.86
Office Space/Commercial Space	30000	10	300000	70	4.29
Office Space/Commercial Space	40000	10	400000	70	5.71
Office Space/Commercial Space	50000	10	500000	70	7.14
Warehouse/Industrial Space	5000	18	90000	70	1.29
Warehouse/Industrial Space	10000	18	180000	70	2.57
Warehouse/Industrial Space	20000	18	360000	70	5.14
Warehouse/Industrial Space	30000	18	540000	70	7.71
Warehouse/Industrial Space	40000	18	720000	70	10.29
Warehouse/Industrial Space	50000	18	900000	70	12.86

90 grams/hr

	Dimensions		VOLUME	MACHINE OUTPUT	TIME REQUIRED TO DISINFECT
	Square Feet	Ceiling Height	Cubic Feet	Grams Per Hour	Hours
Office Space/Commercial Space	5000	10	50000	90	0.56
Office Space/Commercial Space	10000	10	100000	90	1.11
Office Space/Commercial Space	20000	10	200000	90	2.22
Office Space/Commercial Space	30000	10	300000	90	3.33
Office Space/Commercial Space	40000	10	400000	90	4.44
Office Space/Commercial Space	50000	10	500000	90	5.56
Warehouse/Industrial Space	5000	18	90000	90	1.00
Warehouse/Industrial Space	10000	18	180000	90	2.00
Warehouse/Industrial Space	20000	18	360000	90	4.00
Warehouse/Industrial Space	30000	18	540000	90	6.00
Warehouse/Industrial Space	40000	18	720000	90	8.00
Warehouse/Industrial Space	50000	18	900000	90	10.00

110 grams/hr

	Dimensions		VOLUME	MACHINE OUTPUT	TIME REQUIRED TO DISINFECT
	Square Feet	Ceiling Height	Cubic Feet	Grams Per Hour	Hours
Office Space/Commercial Space	5000	10	50000	110	0.45
Office Space/Commercial Space	10000	10	100000	110	0.91
Office Space/Commercial Space	20000	10	200000	110	1.82



Office Space/Commercial Space
 Office Space/Commercial Space
 Office Space/Commercial Space
 Warehouse/Industrial Space
 Warehouse/Industrial Space
 Warehouse/Industrial Space
 Warehouse/Industrial Space
 Warehouse/Industrial Space
 Warehouse/Industrial Space

30000	10	300000	110	2.73
40000	10	400000	110	3.64
50000	10	500000	110	4.55
5000	18	90000	110	0.82
10000	18	180000	110	1.64
20000	18	360000	110	3.27
30000	18	540000	110	4.91
40000	18	720000	110	6.55
50000	18	900000	110	8.18

130 grams/hr

Office Space/Commercial Space
 Office Space/Commercial Space
 Office Space/Commercial Space
 Office Space/Commercial Space
 Office Space/Commercial Space
 Office Space/Commercial Space
 Warehouse/Industrial Space
 Warehouse/Industrial Space
 Warehouse/Industrial Space
 Warehouse/Industrial Space
 Warehouse/Industrial Space
 Warehouse/Industrial Space

Dimensions		VOLUME	MACHINE OUTPUT	TIME REQUIRED TO DISINFECT
Square Feet	Ceiling Height	Cubic Feet	Grams Per Hour	Hours
5000	10	50000	130	0.38
10000	10	100000	130	0.77
20000	10	200000	130	1.54
30000	10	300000	130	2.31
40000	10	400000	130	3.08
50000	10	500000	130	3.85
5000	18	90000	130	0.69
10000	18	180000	130	1.38
20000	18	360000	130	2.77
30000	18	540000	130	4.15
40000	18	720000	130	5.54
50000	18	900000	130	6.92

150 grams/hr

Office Space/Commercial Space
 Office Space/Commercial Space
 Office Space/Commercial Space
 Office Space/Commercial Space
 Office Space/Commercial Space
 Office Space/Commercial Space
 Warehouse/Industrial Space

Dimensions		VOLUME	MACHINE OUTPUT	TIME REQUIRED TO DISINFECT
Square Feet	Ceiling Height	Cubic Feet	Grams Per Hour	Hours
5000	10	50000	150	0.33
10000	10	100000	150	0.67
20000	10	200000	150	1.33
30000	10	300000	150	2.00
40000	10	400000	150	2.67
50000	10	500000	150	3.33
5000	18	90000	150	0.60



Warehouse/Industrial Space
Warehouse/Industrial Space
Warehouse/Industrial Space
Warehouse/Industrial Space
Warehouse/Industrial Space

10000	18	180000	150	1.20
20000	18	360000	150	2.40
30000	18	540000	150	3.60
40000	18	720000	150	4.80
50000	18	900000	150	6.00